



CERTIFICATE

No. B 103722 0003 Rev. 00

Holder of Certificate: Dongguan Slocable Photovoltaic

Technology Co., Ltd.
Huawei Scientific Valley NO.1
Viangaban Bood, Delingsban To.

Xiangshan Road, Dalingshan Town

523812 Dongguan City, Guangdong Province PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies):

Certification Mark:

103722



Product: Electric Cables

(Electric cables for photovoltaic systems with

a voltage rating of 1,5 kV DC)

Model(s): 62930 IEC 131 1x2.5 mm², 1x4 mm², 1x6 mm²,

1x10 mm²

Parameters: Rated voltage: DC 1500 V (between conductors and

between conductor and earth)

AC Uo/U: 1.0/1.0 kV

Ambient temperature: -40 °C to +90 °C

Colour of insulation: white Colour of sheath: black / red

Tested according to: IEC 62930(ed.1)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64290190058701 **Valid until:** 2025-03-04

Date, 2020-03-06 (Symbol Zhao)

TÜV®